

Marco le Poole
Drukwerkdeal
Keulenstraat 4
NL-7418 ET Deventer
The Netherlands

Your notice of	Your reference	Date
14-12-2020	Drukwerkdeal promotioneel masker 14.12.2020	15-12-2020

Analysis Report 2020-18

Accreditation AMIBM for these tests pending

Required tests

EN 14683 (2019) +
AC (2019)

EN 14683 (2019) +
AC (2019)

Conformity
assessment –
Requirements for
certifying
community masks

EN 14683 (2019) -
annex B (2019)

EN 14683 (2019) -
annex C (2019)

NEN-spec 1-
2:2020-11-0

Bacterial filtration
efficiency

Breathability
(differential pressure)

Visual and manual
inspection


SOP used

AMIBM SOP 2.0;
Date 29.6.2020

AMIBM SOP 1.0;
Date 29.6.2020

AMIBM SOP 1.0
Date 12.12.2020

Identification number	Information given by the client	Date of receipt
2020-18	Drukwerkdeal promotioneel masker 14.12.2020	14-12-2020



Dr. Richard Ramakers

Visiting address
Urmonderbaan 22
6167 RD Geleen

Postal address
P.O. Box 616
6200 MD Maastricht
The Netherlands

T +31 (0)43 388 22 22
F +31 (0)43 388 52 47

Bank account: 065.76.18.705
IBAN: NL05 INGB 0657 6187 05
BIC: INGBNL2A
VAT identifier EU
NL0034.75.268.B01

www.maastrichtuniversity.nl
Masktest-amibm@maastrichtuniversity.nl

KvK nr.: 50169181

Bacterial filtration efficiency

Date of ending the test	15.12.2020
Standard used	EN 14683 (2019) - annex B (2019)
Product standard	EN 14683 (2019) + AC (2019)
SOP version used	AMIBM SOP 2.0; Date 29.6.2020
Reference	Drukwerkdeal promotioneel masker 14.12.2020
Number of tested masks	5
BFE area tested	$\pm 49 \text{ cm}^2$
Mask conditioning	$\geq 4 \text{ h}$ at $21 \pm 5^\circ \text{ C}$ and $85 \pm 5\% \text{ RH}$
Mask/bacteria contact side	Inner side
Challenge bacterial strain used	<i>Staphylococcus aureus</i> ATCC6538
Bacterial challenge per test	1700-3000 CFU
Total test time	1 min. challenge delivery + 1 min. without challenge (continuous air flow)
Flow rate	28.3 l/min
Positive control	Tests performed without filter in air stream
Negative control	Test performed without bacterial challenge
Deviation from Standard	NO



Results

B = Bacterial filtration efficiency (%)

C = Mean of the total plate counts for the positive control runs

T = Total count for the tested mask specimen

$$B = \frac{(C - T)}{C} \times 100$$

Mask #	B (%)
1	84.0
2	81.2
3	81.2
4	79.3
5	81.7

*no detected colony on any TSA sampler plates

Average B: 81,5%

Mean particle size of the bacterial aerosol challenge: 2,7 µm

Controls

Mean positive controls 1751 CFU

Negative control <1 CFU

This test report is valid for products used in relation to the current Covid-19 health crisis and for products which are not entering the regular distribution channels. Cfr Commission Recommendation (EU) 2020/403 of 13 March 2020 on conformity assessment and market surveillance procedures within the context of the COVID-19 threat.

Conclusion: The Bacterial Filter Efficiency is 81,5 % ≥ 70%. **pass** for community masks.

Breathability (differential pressure)

Date of testing	14.12.2020
Standard used	EN 14683 (2019) - annex C (2019)
Product standard	EN 14683 (2019) + AC (2019)
SOP version used	AMIBM SOP 1.0; Date 29.6.2020
Reference	Drukwerkdeal promotioneel masker 14.12.2020
Number of tested masks	5
Number of areas per mask	5 (see Figure 1)
Dimensions of the areas	Discs with diameters of 2.5 cm
Surface areas	4.9 cm ²
Flow rate	8 l/min
Mask conditioning	≥4 h at 21 ± 5° C and 85 ± 5% RH
Direction of air flow	From inside of the mask to the outside
Deviation from Standard	NO




Figure 1: Distribution of the test areas in the mask specimen.

Results

Sample 1:	Drukwerkdeal promotioneel masker				Date	14.12.2020
Pa	Mask 1	Mask 2	Mask 3	Mask 4	Mask 5	
Section A	175	151	178	116	163	
Section B	177	182	176	138	157	
Section C	166	163	173	133	155	
Section D	159	155	172	153	148	
Section E	171	154	155	144	157	
Pa/cm2	Mask 1	Mask 2	Mask 3	Mask 4	Mask 5	
Section A	35.7	30.8	36.3	23.7	33.3	
Section B	36.1	37.1	35.9	28.2	32.0	
Section C	33.9	33.3	35.3	27.1	31.6	
Section D	32.4	31.6	35.1	31.2	30.2	
Section E	34.9	31.4	31.6	29.4	32.0	
Mittelwert	34.6	32.9	34.9	27.9	31.8	
STD	1.5	2.6	1.9	2.8	1.1	
Average ΔP :				32.4 Pa/cm2		

Conclusion: Breathability = $32,4 \text{ Pa/cm}^2 \leq 40 \text{ Pa/cm}^2$: pass for community masks.

Manual and Visual inspection

Inspection checklist for testing community masks according to NCS 1-2								
Drukwerkdeal promotieel masker, 14.12.2020								
	Rating						Average score	Pass/fail
	Tester 1 (Ramakers)		Tester 2 (Bortesi)		Tester 3 (Besen)			
Mandatory property	Mask 1	Mask 2	Mask 1	Mask 2	Mask 1	Mask 2		
1 No sharp seams	Pass	Pass	Pass	Pass	Pass	Pass		Pass
2 No sharp ridges	Pass	Pass	Pass	Pass	Pass	Pass		Pass
3 No staples used	Pass	Pass	Pass	Pass	Pass	Pass		Pass
4 No exhalation valve	Pass	Pass	Pass	Pass	Pass	Pass		Pass
Elastic band is strong enough to hold the mask in place without making it too tight or uncomfortable	8	8	9	9	6	6	7.7	Pass
6 Fixation allows easy putting on and off	8	8	8	8	7	7	7.7	Pass
Fixation is strong enough to hold the mask in place even when moving the head. Test by putting the mask on and off five times.	8	8	7	7	6	6	7.0	Pass
Mask can be pulled tight so that it is smooth and without folds at the edge	8	8	8	8	7	7	7.7	Pass
9 Visual defects	Pass	Pass	Pass	Pass	Pass	Pass		Pass
10 Packaging has no irregularities, damage and is of appropriate size	6	6	6	6	6	6	6.0	Pass
Additional mandatory property for masks intended for children								
Mask has head fastening behind the ears without adjustable elements and without fastening that has to be tied								
Target group: adults	Fitting criteria fulfilled: mask dimensions are suitable for the specified target group, no fitting-hampering faults found							
	Pass	Pass	Pass	Pass	Pass	Pass		Pass
					Overall assessment adult mask: Pass			
					Overall assessment children mask:			

Conclusion: all scores are "pass" or $\geq 5,5$: pass for manual and visual inspection for community masks.